

ELECTRICAL COMPLIANCE & TEST CERTIFICATE

EXHIBITION: DATE:

VENUE: HALL:

STAND Nos: MAIN SIZE:

I certify that the installation has been checked, tested and is complete. The electrical installation on the exhibition complies with the requirements of the Electricity at Work Regulations 1989 and the EVA Regulations for Stand Electrical Installations 1998, current IEE regulations and any amendments thereto.

All final circuits rated up to 30 amps are protected by an RCD with a 30mA operating current. All RCD units have been performance tested and carry a current test label.

SIGNED:

NAME:

POSITION:

ELECTRICAL TESTS (test instrument readings are required for insulation and continuity)

Visual.....Checked

Insulation..... Meg Ohms.

Continuity.....Ohms

Polarity.....Checked

RCD Test Label.....Checked